

Test Verification of Conformity

Verification Number: 19-000923-001

On the basis of the tests undertaken, the sample of the below product have been found to comply with the requirements of the referenced standards at the time the tests were carried out. This verification is part of the full test report and should be read in conjunction with it.

Applicant Name & Address: **MAS INDUSTRIES PVT. LTD.**
Plot No. D/378, TTC Industrial Area,
Turbhe MIDC, Navi Mumbai – 400705. Maharashtra. India.

Product Description: Control Panel

Ratings & Principle Characteristics: 380/415 V a.c., 50/60Hz, 3P 4W, 30kW Max.

Models/Type References: Two Speed, VVVF & MAS ARD Controller

Brand Name: 
MAS INDUSTRIES PVT. LTD.

Standards / Directives: **IEC 60204-1:2016:** Safety of machinery - Electrical equipment of machines - Part 1: General requirements.
GS251/1994: Electric Lifts For Passengers Or Goods- Part 4
For Safety measures for Electrical Installation of Lifts.

Verification Issuing Office Name & Address: **Intertek India Private Limited**
'F' Wing, TEX Centre, Chandivali Farm Road,
Andheri (E), Mumbai - 400 072, India.

Test Report Number: CE-JOB-MUM-19-000923-001 issued on 12th Aug 2019



Signature

Name: Mr. Gokul Mahajan

Position: Senior Manager – Operations

Date: 12-08-2019

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.